



MONTEREY COUNTY REGIONAL FIRE DISTRICT PREVENTION DIVISION

RESIDENTIAL FIRE SPRINKLER SYSTEM Rough Inspection Checklist

APPLICANT: _____ APN #: _____

PROJECT LOCATION: _____

SPRINKLER CONTRACTOR: _____

	DATE	FAIL	PASS	DATE
1. RISER CONSTRUCTION AND LOCATION APPROVAL				
a. Drain Valve	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____
b. Backflow Device	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____
c. Alarm Activation Device	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____
d. Inspector's Test Valve	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____

2. PRESSURE TEST APPROVAL				
a. System tested at 200 psi for 2 hours	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____
b. Pressure relieved to _____ psi	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____

3. SPRINKLER HEADS (INSTALLED PER PLANS)				
a. Head type is: _____	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____
b. Installation and placement (spacing)	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____
c. Field changes to code, mark plans	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____
d. Field changes require as-builts and new calculations	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____

4. PIPING				
a. Sizing per plans	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____
b. Hangers per codes/prevent upward movement	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____

5. APPROVED FIRE DEPT. PLANS VS. ACTUAL INSTALLATION				
* Submit new plans and calculations	_____	<input type="checkbox"/>	<input type="checkbox"/>	_____

NOTE: CPVC plastic pipe in the garage shall not be exposed unless it is installed above a smooth, flat, horizontal ceiling. Sprinklers that have been listed "quick response" or "residential" must be used.

CORRECTIONS AND NOTES: _____

ROUGH-IN SPRINKLER INSPECTION APPROVED	
BY: _____	BLDG. PERMIT # _____
DATE: _____	